



**Cable ID: CAB B 03**

**Test Summary: PASS**

Date / Time: 07/02/2004 02:28:36pm  
**Headroom: 8.59 dB (Loss)**  
**Test Limit: 100BASE-FX**  
 Cable Type: Multimode

Operator: Netlink Cabling Ltd  
 Software Version: V02.10

Model: CertiFiber  
 Main S/N: 55C04E00020  
 Remote S/N: 55D04E00025

n = 1.4966  
 Propagation Delay (ns) 662  
 Length (m), Limit 2000.0 132.6 PASS

Direction	A-B	A-B
Wavelength (nm)	850	1300
Result	N/A	PASS
Loss (dB)	2.13	2.41
Loss Limit (dB)		11.00
Loss Margin (dB)		8.59

Compliant Network Standards:

TIA568B CNT	100BASE-FX	10BASE-FL	1000BASE-SX
1000BASE-LX	ATM155 1300	ATM155 850	ATM622 850
FDDI ORIG	TOKEN RING	FIBCHN266	