



Cable ID: C1-C4/02

Test Summary: PASS

Date / Time: 03/15/2006 01:34:45pm
Headroom: 1.05 dB (Loss)
Test Limit: 1000BASE-SX
 Cable Type: 50 & 62.5/125um

Operator: D.Fleming
 Software Version: V02.10

Model: CertiFiber
 Main S/N: 55C04E00020
 Remote S/N: 55D04E00025

n = 1.4966
 Propagation Delay (ns) 536
 Length (m), Limit 550.0 107.4 PASS

| | | |
|------------------|------|------|
| Direction | A-B | A-B |
| Wavelength (nm) | 850 | 1300 |
| Result | PASS | N/A |
| Loss (dB) | 2.15 | 1.41 |
| Loss Limit (dB) | 3.20 | |
| Loss Margin (dB) | 1.05 | |

Compliant Network Standards:

| | | | |
|-------------|-------------|------------|-------------|
| TIA568B CNT | 100BASE-FX | 10BASE-FL | 1000BASE-SX |
| 1000BASE-LX | ATM155 1300 | ATM155 850 | ATM622 850 |
| FDDI ORIG | TOKEN RING | FIBCHN266 | |